CERTIFICATE OF PRODUCT CERTIFICATION

CERTIFICATE NO.: CQC23012378821

Valid from: Jun.18,2024

Valid until:long-term

NAME AND REGISTERED ADDRESS OF THE APPLICANT	Transparent Power Technology Co.,Ltd. Room 417, Floor 4, Building 2, Zhengtai Yueqing iot Sensor Industrial Park, No. 1, Changcheng East Road, Liushi City, Yueqing City, Wenzhou City, Zhejiang Province
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	Transparent Power Technology Co.,Ltd. Room 417, Floor 4, Building 2, Zhengtai Yueqing iot Sensor Industrial Park, No. 1, Changcheng East Road, Liushi City, Yueqing City, Wenzhou City, Zhejiang Province
NAME AND LOCATION OF THE FACTORY	Transparent Power Technology Co.,Ltd. Xiaofang village, Beibaixiang town, Yueqing City, Wenzhou City, Zhejiang Province, P.R.China
PRODUCT NAME, MODEL AND SPECIFICATION	Circuit-breakers for IOT IOTB2-80、IOTB2-80H；Uimp：4kV；Ui：690V；Ue：AC230V（1P、2P），AC400V（3P、4P）；In：6A、10A、16A、20A、25A、32A、40A、50A、63A、80A；Normal type：Ics：6kA、Icu：6kA；H：Ics：7.5kA、Icu：10kA；Over current release type：Thermal-magnetic type;Selectivity Category：A；Remote automatic control mode,Manual control mode;Controlling signal: Communication protocol (RS485,WIFI);suitable for isolation;Poles:1P,2P,3P,4P
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	CQC1148-2020
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-382301-2020.

Date of original issued: Mar.07,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn

SIGNATURE: 谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司 1101061026946