产品认证证书

证书编号：CQC24012452843

发证日期：2024 年 11 月 25 日
有效期至：长期有效

委托人名称及注册地址	透明电力科技有限公司 浙江省温州市乐清市柳市镇长东路 1 号（正泰乐清物联网传感器产业园 2 号楼 4 层 417 室）
制造商名称及注册地址	透明电力科技有限公司 浙江省温州市乐清市柳市镇长东路 1 号（正泰乐清物联网传感器产业园 2 号楼 4 层 417 室）
生产企业名称及生产地址	透明电力科技有限公司 浙江省温州市乐清市北白象镇小方村
产品名称和系列、规格、型号	物联网断路器 IOTM2LR-250S、IOTM2LR-250M、IOTM2LR-250H、IOTM2LR-125S、IOTM2LR-125M、IOTM2LR-125H；具体参数详见附页
产品标准和技术要求	CQC1148-2020
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC11-382301-2020 认证规则的要求，特发此证。
本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站（www.cnca.gov.cn）查验证书信息

签发：谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司 11010610269466

中国质量认证中心有限公司
中国·北京·南四环西路188号9区 100070
电话：+86 10 83886666
http://www.cqc.com.cn

CERTIFICATE OF PRODUCT CERTIFICATION

CERTIFICATE NO.: CQC24012452843

Valid from: Nov.25,2024

Valid until:long-term

NAME AND REGISTERED ADDRESS OF THE APPLICANT	Transparent Power Technology Co.,Ltd. Room 417, Floor 4, Building 2, Zhengtai Yueqing iot Sensor Industrial Park, No. 1, Changcheng East Road, Liushi City, Yueqing City, Wenzhou City, Zhejiang Province
NAME AND REGISTERED ADDRESS OF THE MANUFACTURER	Transparent Power Technology Co.,Ltd. Room 417, Floor 4, Building 2, Zhengtai Yueqing iot Sensor Industrial Park, No. 1, Changcheng East Road, Liushi City, Yueqing City, Wenzhou City, Zhejiang Province
NAME AND LOCATION OF THE FACTORY	Transparent Power Technology Co.,Ltd. Xiaofang village, Beibaixiang town, Yueqing City, Wenzhou City, Zhejiang Province, P.R.China
PRODUCT NAME, MODEL AND SPECIFICATION	Circuit-breakers for IOT IOTM2LR-250S、IOTM2LR-250M、IOTM2LR-250H、IOTM2LR-125S、IOTM2LR-125M、IOTM2LR-125H; See the Appendix
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS	CQC1148-2020
TYPE OF CERTIFICATION SCHEMES	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-382301-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn

SIGNATURE: 谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司 1101061026946

产品认证证书

证书编号：CQC24012452843　　第 1 页 /共 1 页

本证书及附件应同时使用，信息查验说明见证书页　　纸号：

IOTM2LR-250S、IOTM2LR-250M、IOTM2LR-250H、IOTM2LR-125S、IOTM2LR-125M、IOTM2LR-125H；
Ue：AC380V/400V/415V；
Ui：1000V；
Uimp：12kV；
In：125A（Ir：50A~125A 可调）、250A（Ir：100A~250A 可调）；
剩余电流脱扣器类型：电子式；
过电流脱扣器类型：电子式；
额定剩余动作类型：AC 型；
IΔm：25%Icu；
IΔn：30mA（仅非延时）/50mA/75mA/100mA/200mA/300mA/500mA/800mA/1000mA（非延时型、延时型）分级可调；
S 型：Ics：35kA；Icu：50kA；
M 型：Ics：50kA；Icu：65kA；
H 型：Ics：70kA；Icu：100kA；
Icw：10kA/1s；
选择性类别：B 类；
极数：3P+N（三个保护极，N 极常通，不适用于隔离用）；4P（三个保护极，N 极可开闭，适用于隔离用）；
30mA 产品不具备重合闸功能，自动重合闸时间：20s~60s；
控制方式：远程合分、手动合分；控制信号：通信协议（RS485、4G 控制）

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司 11010610269466

中国质量认证中心有限公司
中国·北京·南四环西路188号9区 100070
电话：+86 10 83886666
http://www.cqc.com.cn